

Emission Test Certificate

Thursday, 20th October 2016

Supplier: The Laminex Group Technology Centre (22 Trewin St, Wendouree, VIC, 3355)

Sample Description: Laminex Vinyl Wrapped MR MDF E0 door (19831)



Date received: 10th October 2016

Date Tested: October 2016 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data:

Green Building Council of Australia Green Star Interiors v1.1 – 12.1.2B	Laminex Vinyl Wrapped MR MDF E0 door (19831)
Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m ² /hr	Total Volatile Organic Compound Emission Rate: <0.005 mg/m ² /hr




Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Dac Duong
PhD, BEng (Chemical Engineer)
Laboratory Technician

CV161014